

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Uninterruptible power supply

Name and address of the applicant

APC by Schneider Electric
Boston ONE Campus, 800 Federal Street,
ANDOVER MA 01810-1067
UNITED STATES OF AMERICA

Name and address of the manufacturer

APC by Schneider Electric
Boston ONE Campus, 800 Federal Street,
ANDOVER MA 01810-1067
UNITED STATES OF AMERICA

Name and address of the factory

AMERICAN POWER CONVERSION CORPORATION
(A.P.C.) B.V.
Lot 3, Block 14, Phase III, PEZA, 4106 ROSARIO, CAVITE
PHILIPPINES*Note: When more than one factory, please report on page 2*☒ Additional Information on page 2

Ratings and principal characteristics

AC 220-240 V, 50/60 Hz, max.16 A, max.3000 VA

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

CTF Stage 2

Model / Type Ref.

Smart UPS
(for model table and matrix see testreport)

Additional information (if necessary may also be reported on page 2)

CB History:
Date of origin: 2018-02-23
Reason for M1: Addition of 2 alternate models
SMT2200UXI-CH, SMT3000UXI-CH☐ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 62040-1:2008
IEC 62040-1:2008/AMD1:2013

As shown in the Test Report Ref. No. which forms part of this Certificate

275862-TL4-1

This CB Test Certificate is issued by the National Certification Body

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
Zertifizierungsstelle und internat. Angelegenheiten
Certification Body and internat. Affairs

Date: 2021-01-19

Signature:



J. Richter

AMERICAN POWER CONVERSION CORPORATION
(A.P.C.) B.V.
Lot 10, Block 16, Phase IV, 4106 PEZA, ROSARIO,
CAVITE
PHILIPPINES

International Precision Assemblies, Inc.
Blk 17, Lot 2 Phase IV, CEPZA Rosario, 4106 Cavite
PHILIPPINES

Additional information (if necessary)

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
Zertifizierungsstelle und internat. Angelegenheiten
Certification Body and internat. Affairs

Date: 2021-01-19

Signature:



J. Richter



Test Report issued under the responsibility of:



TEST REPORT
IEC 62040-1
Uninterruptible power systems (UPS) –
Part 1: General and safety requirements for UPS

CB DE1-59636/A2/M1

Report Number..... : 275862-TL4-1

Date of issue..... : 2021-01-18

Total number of pages..... : 166

Name of Testing Laboratory : **VDE** Prüf- und Zertifizierungsinstitut GmbH
preparing the Report : **VDE** *Testing and Certification Institute*

Applicant's name..... : APC by Schneider Electric

Address..... : Boston ONE Campus; 800 Federal Street; Andover MA 01810-1067; USA

Test specification:

Standard..... : IEC 62040-1:2008 (First Edition) + Am 1: 2013

Test procedure..... : CB Scheme

Non-standard test method : N/A

Test Report Form No. : IEC62040_1D

Test Report Form(s) Originator.... : TÜV Rheinland Japan Ltd.

Master TRF : Dated 2016-08

Copyright © 2016 IEC System of Conformity Assessment Schemes for Electrotechnical Equipment and Components (IECEE System). All rights reserved.

This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.

If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.

This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.

General disclaimer:

The test results presented in this report relate only to the object tested.

This report shall not be reproduced, except in full, without the written approval of the Issuing CB Testing Laboratory. The authenticity of this Test Report and its contents can be verified by contacting the NCB, responsible for this Test Report.

Test item description:	Uninterruptible power supply
Trade Mark:	 by Schneider Electric
Manufacturer:	APC by Schneider Electric; Boston ONE Campus; 800 Federal Street; Andover MA 01810-1067; USA
Model/Type reference	Smart UPS (See table below and model matrix Appendix 1 for details)
Ratings:	See table next page

Model/Type reference:	Rating(s) :	
SUA2200I, DLA2200I, DLT2200I, SMT2200I, SMT2200I-CH	Input:	AC 220-240 V; max.15A; 50/60 Hz
	Output:	AC 220-240 V; max.10A; 50/60 Hz; max.2200 VA; 1980W
SUA2200RMI2U	Input:	AC 220-240 V; max.10A; 50/60 Hz
	Output:	AC 220-240 V; 50/60 Hz; max. 2200 VA; 1980W
SUA2200XLI SUA2200RMXLI3U	Input:	AC 220-240 V; max.15A; 50/60 Hz
	Output:	AC 220-240 V; 50/60 Hz; max. 2200 VA; 1980W
SUA3000I, SMT3000I, SMT3000I-CH	Input:	AC 220-240 V; max.15A; 50/60 Hz
	Output:	AC 220-240 V; max.14A; 50/60 Hz; max.3000 VA; 2700W
SUA3000RMI2U	Input:	AC 220-240 V; max.13A; 50/60 Hz;
	Output:	AC 220-240 V; 50/60 Hz; max.3000 VA; 2700W
SUA3000XLI SUA3000RMXLI3U SMT3000RMI2U SMT3000RMI2UNC DLT3000RMI2U	Input:	AC 220-240 V; max.15A; 50/60 Hz;
	Output:	AC 220-240 V; 50/60 Hz; max. 3000 VA; 2700W
SMT2200RMI2U SMT2200RMI2UNC	Input:	AC 220-240 V; max.12A; 50/60 Hz;
	Output:	AC 220-240 V; 50/60 Hz; max.2200 VA; 1980W
SMC3000I, SMC3000I-CH SMC3000RMI2U, SMC3000I2U-CH	Input:	AC 220-240 V; 16A, 50/60 Hz
	Output:	AC 220-240 V; 13.63A, 50/60 Hz; max. 3000 VA; 2100W
SMT2200IC SMT2200RMI2UC, SMT2200RMI2U-CH DLT2200IC, DLT2200RMI2UC SMT2200UXI-CH (added by this update)	Input:	AC 220-240 V; 13A, 50/60 Hz
	Output:	AC 220-240 V; 10A, 50/60 Hz; max. 2200 VA; 1980W
SMT3000IC SMT3000RMI2UC SMT3000RMI2U-CH DLT3000IC , DLT3000RMI2UC SMT3000UXI-CH (added by this update)	Input:	AC 220-240 V; 16A, 50/60 Hz
	Output:	AC 220-240 V; 13.64A, 50/60 Hz; max. 3000 VA; 2700W
Ambient:		40 °C